

## **Submittal Data Sheet**

4.0-Ton Round Flow Sensing Cassette FXFQ48TVJU

PERFORMANCE			
Indoor Unit Model No.	FXFQ48TVJU	Indoor Unit Name:	4.0-Ton Round Flow Sensing Cassette
Туре:	Cassette	Rated Cooling Conditions:	Indoor (°F DB/WB): 80 / 67 Ambient (°F DB/WB): 95 / 75
Rated Cooling Capacity (Btu/hr):	48,000	Rated Heating Conditions:	Indoor (°F DB/WB): 70 / 60 Ambient (°F DB/WB): 47 / 43
Sensible Capacity (Btu/hr):	35,000	Rated Piping Length(ft):	
Cooling Input Power (kW):	0.220	Rated Height Separation (ft):	
Rated Heating Capacity (Btu/hr):	54,000		
Heating Input Power (kW):	0.20		

INDOOR UNIT DETAILS			
Power Supply (V/Hz/Ph):	208-230 / 60 / 1	Airflow Rate (HH/H/L) (CFM):	1,218/971/742
Power Supply Connections:	L1, L2, Ground	Moisture Removal (Gal/hr):	
Min. Circuit Amps MCA (A):	1.8	Gas Pipe Connection (inch):	5/8
Max Overcurrent Protection (MOP) (A):	15	Liquid Pipe Connection (inch):	3/8
Dimensions (HxWxD) (in):	11-5/16 x 33-1/16 x 33-1/16	Condensate Connection (inch):	1-1/4
Net Weight (lb):	58	Sound Pressure (H/L) (dBA):	40/34
Ext. Static Pressure (Rated/Max) (inWg):	I	Sound Power Level (dBA):	

Daikin North America LLC, 5151 San Felipe, Suite 500, Houston, TX, 77056


Submittal Date: 10/1/2018 4:43:07 AM Page 2 of 3





## **Submittal Data Sheet**


4.0-Ton Round Flow Sensing Cassette FXFQ48TVJU


## **DIMENSIONAL DRAWING**











Unit: in. (mm)

ITEM	PART NAME	REMARK
1	Liquid pipe connection	$\phi$ 3/8 ( $\phi$ 9.5) Flare connection
2	Gas pipe connection	$\phi$ 5/8 ( $\phi$ 15.9) Flare connection
3	Drain pipe connection	VP25 (0. D. φ1-1/4 (φ32), I. D. φ1 (φ25))
4	Power supply entry hole	
5	Transmission wiring entry hole	
6	Air Outlet	
7	Air Inlet grille	
8	Corner decoration cover	
9	Sensor	Infrared presence sensor Infrared floor sensor
10	Knock out hole	φ3-15/16 (φ100)

Vithout panel	H1	11-3/4 (298)
	W1	33-1/16 (840)
	D1	33-1/16 (840)
With panel	H2	13-5/16 (338)
	W2	37-3/8 (950)
	D2	37-3/8 (950)

Notes) 1. Location of the nameplates:

- Unit body: on the control box cover. - Decoration panel: on the panel frame at the motor side under the corner cover.
- 2. Make sure the spacing between the ceiling and the cassette is no more than 1-3/8" (35mm). MAX ceiling opening: 35-7/8" (910mm).
- 3. When the conditions exceed  $86^\circ F(30^\circ C)$  and RH 80% in the ceiling or fresh air is inducted into the ceiling an additional insulation is required (polyethylene foam, thickness 3/8''(10mm) or more).

Note: For additional dimensional data and clearance information, refer to Engineering Data

Daikin North America LLC, 5151 San Felipe, Suite 500, Houston, TX, 77056

www.daikinac.com www.daikincomfort.com

Daikin City Generated Submittal Data

(Daikin's products are subject to continuous improvements. Daikin reserves the right to modify product design, specifications and information in this data sheet without notice and without incurring any obligations)

Submittal Date: 10/1/2018 4:43:07 AM Page 3 of 3